



**MAKE SURE VOLTAGE SETTINGS ON 3101B AND LED MATCH POWER SUPPLY.**

# MODEL #3101BxDYN TERMINAL STRIP

PWR IN		RESET		BYPASS		DEM			DYN								
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
												NC	C	NO	NC	C	NO



**OPERATION:**  
 RED LED - NORMAL/DOOR CLOSED  
 GREEN LED - NORMAL/DOOR OPEN  
 RED LED & BUZZER - ALARM/DOOR CLOSED  
 GREEN LED & BUZZER - ALARM/DOOR OPEN

**DynaLock**  
 DynaLock Corporation  
 705 Emmett Street • Bristol, CT 06010  
 Tel: (860) 582-4761 • Fax: (860) 585-0338

*Wiring Diagram*

DRWN:	Date:
CHK'D:	Date:
CHK'D:	Date:
APPV'D:	Date:

Title:		Page		Scale:	Size:	Drawing #:	REV:
WIRING DIAGRAM - USING MODEL #6370 SINGLE ZONE STATION WITH 3101B		1 Of 1		—	A	900405	—